

Weekly DI TESTING

COND= Conductivity
RES = Resistivity
TDS = Total Dissolved Solids
ORP_PPM = Free Chlorine

111	COND	0.06	uS	8/8/11	12:19:24
112	RES	18.00	MOhm	8/8/11	12:19:30
113	TDS	0.00	ppm	8/8/11	12:19:36
114	ORP_PPM	0.10	ppm	8/8/11	12:19:42
115	pH	9.70		8/8/11	12:19:57
116	COND	0.08	uS	8/15/11	8:03:53
117	RES	16.70	MOhm	8/15/11	8:04:06
118	TDS	0.00	ppm	8/15/11	8:04:19
119	ORP_PPM	----		8/15/11	8:04:32
120	pH	6.70		8/15/11	8:04:45
121	COND	0.05	uS	8/22/11	12:34:48
122	RES	17.10	MOhm	8/22/11	12:34:53
123	TDS	0.00	ppm	8/22/11	12:34:58
124	ORP_PPM	0.10	ppm	8/22/11	12:35:03
125	pH	7.06		8/22/11	12:35:08
126	COND	0.07	uS	8/29/11	12:48:00
127	RES	18.10	MOhm	8/29/11	12:48:05
128	TDS	0.00	ppm	8/29/11	12:48:10
129	ORP_PPM	0.10	ppm	8/29/11	12:48:17
130	pH	6.41		8/29/11	12:48:49
131	COND	0.06	uS	9/5/11	13:35:44
132	RES	18.40	MOhm	9/5/11	13:36:01
133	TDS	0.00	ppm	9/5/11	13:36:26
134	ORP_PPM	0.10	ppm	9/5/11	13:36:42
135	pH	7.94		9/5/11	13:36:52
136	COND	0.00	uS	9/12/11	12:45:04
137	RES	17.00	MOhm	9/12/11	12:45:21
138	TDS	0.00	ppm	9/12/11	12:45:27
139	ORP_PPM	0.10	ppm	9/12/11	12:45:37
140	pH	8.44		9/12/11	12:46:10
141	COND	0.07	uS	9/19/11	12:13:19
142	RES	18.20	MOhm	9/19/11	12:13:35
143	TDS	0.00	ppm	9/19/11	12:13:41
144	ORP_PPM	0.10	ppm	9/19/11	12:13:56
145	pH	7.90		9/19/11	12:14:04
146	COND	0.05	uS	9/26/11	8:11:36
147	RES	17.30	MOhm	9/26/11	8:11:42
148	TDS	0.00	ppm	9/26/11	8:11:45
149	ORP_PPM	0.10	ppm	9/26/11	8:11:48
150	pH	6.04		9/26/11	8:11:59
151	COND	0.05	uS	10/4/11	7:43:55
152	RES	18.00	MOhm	10/4/11	7:44:05
153	TDS	0.00	ppm	10/4/11	7:44:09
154	ORP_PPM	0.10	ppm	10/4/11	7:44:15

155	pH	6.74		10/4/11	7:44:35
156	COND	0.07	uS	10/12/11	9:54:05
157	RES	18.70	MOhm	10/12/11	9:55:13
158	TDS	0.00	ppm	10/12/11	9:55:21
159	ORP_PPM	0.10	ppm	10/12/11	9:55:23
160	pH	7.78		10/12/11	9:55:38
161	COND	0.06	uS	10/28/11	8:29:42
162	RES	16.70	MOhm	10/28/11	8:29:51
163	TDS	0.00	ppm	10/28/11	8:29:58
164	ORP_PPM	0.10	ppm	10/28/11	8:30:03
165	pH	6.83		10/28/11	8:30:13
166	COND	0.05	uS	11/4/11	12:48:10
167	RES	17.70	MOhm	11/4/11	12:48:17
168	TDS	0.00	ppm	11/4/11	12:48:49
169	ORP_PPM	0.10	ppm	11/4/11	12:49:21
170	pH	6.06		11/4/11	12:49:53
171	COND	0.06	uS	11/11/11	9:34:59
172	RES	18.50	MOhm	11/11/11	9:35:50
173	TDS	0.00	ppm	11/11/11	9:35:56
174	ORP_PPM	0.10	ppm	11/11/11	9:36:00
175	pH	6.33		11/11/11	9:36:10
176	COND	0.05	uS	11/18/11	8:03:53
177	RES	18.40	MOhm	11/18/11	8:04:06
178	TDS	0.00	ppm	11/18/11	8:04:19
179	ORP_PPM	0.10	ppm	11/18/11	8:04:32
180	pH	7.00		11/18/11	8:04:45
181	COND	0.06	uS	11/18/11	7:28:09
182	RES	18.30	MOhm	11/18/11	7:28:56
183	TDS	0.00	ppm	11/18/11	7:29:14
184	ORP_PPM	0.10	ppm	11/18/11	7:29:42
185	pH	7.89		11/18/11	7:30:15
186	COND	0.05	uS	11/23/11	9:38:20
187	RES	17.80	MOhm	11/23/11	9:38:24
188	TDS	0.00	ppm	11/23/11	9:38:28
189	ORP_PPM	0.10	ppm	11/23/11	9:38:30
190	pH	7.33		11/23/11	9:38:52
191	COND	0.05	uS	11/30/11	10:53:13
192	RES	17.10	MOhm	11/30/11	10:54:42
193	TDS	0.00	ppm	11/30/11	10:55:00
194	ORP_PPM	27.72	ppm	11/30/11	10:55:13
195	pH	6.85		11/30/11	10:55:26
196	COND	0.06	uS	12/7/11	9:40:24
197	RES	17.20	MOhm	12/7/11	9:40:26
198	TDS	0.00	ppm	12/7/11	9:40:30
199	ORP_PPM	16.47	ppm	12/7/11	9:40:32
200	pH	7.94		12/7/11	9:40:35
201	COND	0.06	uS	12/14/11	10:15:45
202	RES	18.10	MOhm	12/14/11	10:17:46
203	TDS	0.00	ppm	12/14/11	10:17:55

204	ORP_PPM	----		12/14/11	10:18:16
205	pH	7.95		12/14/11	10:18:31
206	COND	0.07	uS	12/21/11	10:26:54
207	RES	18.6	MOhm	12/21/11	10:27:04
208	TDS	0	ppm	12/21/11	10:27:08
209	ORP_PPM	0.1	ppm	12/21/11	10:27:13
210	pH	6.21		12/21/11	10:27:25
211	COND	0.05	uS	12/28/11	10:27:44
212	RES	17	MOhm	12/28/11	10:27:52
213	TDS	0	ppm	12/28/11	10:27:55
214	ORP_PPM	0.1	ppm	12/28/11	10:27:58
215	pH	6.2		12/28/11	10:28:01
216	COND	0.06	uS	1/3/12	10:28:26
217	RES	17.8	MOhm	1/3/12	10:28:31
218	TDS	0	ppm	1/3/12	10:28:34
219	ORP_PPM	0.1	ppm	1/3/12	10:28:36
220	pH	5.8		1/3/12	10:28:39